

UNITED STATES DEPARTMENT OF COMMERCE United States Patent and Trademark Office Address: COMMISSIONER FOR PATENTS PO Box 1430 Alexasdra, Virginia 22313-1450 www.nepto.gov

APPLICATION NO.	FILING DATE	FIRST NAMED INVENTOR	ATTORNEY DOCKET NO.	CONFIRMATION NO.	
10/549,813	09/19/2005	Masahiro Fushimi	Q89844	1456	
23373 7590 02/11/2008 SUGHRUE MION, PLLC 2100 PENNSYL VANIA AVENUE, N.W.			EXAM	EXAMINER	
			BARRERA, RAMON M		
SUITE 800 WASHINGTON, DC 20037		ART UNIT	PAPER NUMBER		
	111111111111111111111111111111111111111		2832		
			MAIL DATE	DELIVERY MODE	
			02/11/2008	PAPER	

Please find below and/or attached an Office communication concerning this application or proceeding.

The time period for reply, if any, is set in the attached communication.

Application No. Applicant(s) 10/549.813 FUSHIMI ET AL. Office Action Summary Examiner Art Unit RAMON M. BARRERA 2832 -- The MAILING DATE of this communication appears on the cover sheet with the correspondence address --Period for Reply A SHORTENED STATUTORY PERIOD FOR REPLY IS SET TO EXPIRE 3 MONTH(S) OR THIRTY (30) DAYS. WHICHEVER IS LONGER, FROM THE MAILING DATE OF THIS COMMUNICATION. Extensions of time may be available under the provisions of 37 CFR 1.136(a). In no event, however, may a reply be timely filed after SIX (6) MONTHS from the mailing date of this communication. If NO period for reply is specified above, the maximum statutory period will apply and will expire SIX (6) MONTHS from the mailing date of this communication - Failure to reply within the set or extended period for reply will, by statute, cause the application to become ABANDONED (35 U.S.C. § 133). Any reply received by the Office later than three months after the mailing date of this communication, even if timely filed, may reduce any earned patent term adjustment. See 37 CFR 1.704(b). Status 1) Responsive to communication(s) filed on 11/9/07. 2a) This action is FINAL. 2b) This action is non-final. 3) Since this application is in condition for allowance except for formal matters, prosecution as to the merits is closed in accordance with the practice under Ex parte Quayle, 1935 C.D. 11, 453 O.G. 213. Disposition of Claims 4) Claim(s) 1-12 is/are pending in the application. 4a) Of the above claim(s) is/are withdrawn from consideration. 5) Claim(s) _____ is/are allowed. 6) Claim(s) 1.3 and 9 is/are rejected. 7) Claim(s) 2,4-8 and 10-12 is/are objected to. 8) Claim(s) _____ are subject to restriction and/or election requirement. Application Papers 9) The specification is objected to by the Examiner. 10) The drawing(s) filed on is/are; a) accepted or b) objected to by the Examiner. Applicant may not request that any objection to the drawing(s) be held in abeyance. See 37 CFR 1.85(a). Replacement drawing sheet(s) including the correction is required if the drawing(s) is objected to. See 37 CFR 1.121(d). 11) The oath or declaration is objected to by the Examiner. Note the attached Office Action or form PTO-152. Priority under 35 U.S.C. § 119 12) Acknowledgment is made of a claim for foreign priority under 35 U.S.C. § 119(a)-(d) or (f). a) All b) Some * c) None of: Certified copies of the priority documents have been received. 2. Certified copies of the priority documents have been received in Application No. Copies of the certified copies of the priority documents have been received in this National Stage application from the International Bureau (PCT Rule 17.2(a)). * See the attached detailed Office action for a list of the certified copies not received.

| Attachment(s) | Attachment(s

Application/Control Number: 10/549,813

Art Unit: 2832

DETAILED ACTION

Claim Rejections - 35 USC § 102

 The following is a quotation of the appropriate paragraphs of 35 U.S.C. 102 that form the basis for the rejections under this section made in this Office action:

A person shall be entitled to a patent unless -

- (b) the invention was patented or described in a printed publication in this or a foreign country or in public use or on sale in this country, more than one year prior to the date of application for patent in the United States.
- Claims 1, 3, and 9 are rejected under 35 U.S.C. 102(b) as being anticipated by

 Meier.

Meier discloses a circuit breaker characterized by comprising a pair of stationary contactors 9 which are disposed in opposition to each other and each of which is provided with a stationary contact 8, a movable contactor 6 which includes a pair of movable contacts 7 respectively disposed in opposition to the stationary contacts and which is capable of bridging both said stationary contactors, a switching mechanism section 3 which operates when an overcurrent has flowed through said stationary contactors, a crossbar 11 which is engaged with a substantially central part of said movable contactor from a side of said stationary contactors and which separates said movable contactor from said stationary contactors upon the operation of said switching mechanism section (fig. 3), a contact pressure spring 12 which is engaged with said crossbar at one end and with the substantially central part of said movable contactor at the other end and which urges said movable contactor toward said stationary contactors, and arc extinction chambers 5 which are respectively disposed near both end parts of said movable contactor and which extinguish an arc struck at the

Page 3

Application/Control Number: 10/549,813

Art Unit: 2832

separation of said movable contactor from said stationary contactors, characterized in that said crossbar includes a depression portion 10 which extends onto a side of said movable contactor and which depresses said movable contactor in engagement with substantially the central part of said movable contactor, and that an accommodation portion which accommodates said contact pressure spring therein is provided in said depression portion, characterized by comprising a link 20 which interlocks with said switching mechanism section, and a slot which is provided in said crossbar, and that said link and said crossbar are engaged through a pin 18 which is snugly inserted into said slot.

Allowable Subject Matter

3. Claims 2, 4-8, and 10-12 are objected to as being dependent upon a rejected base claim, but would be allowable if rewritten in independent form including all of the limitations of the base claim and any intervening claims.

Response to Arguments

- 4. Applicant's arguments filed 11/9/07 have been fully considered but they are not persuasive. Applicant alleges Meier fails to disclose "a crossbar which is engaged with a substantially central part of said movable contactor from a side of said stationary contactors." The examiner deems this condition is shown in figs. 3 and 4 where it appears that the movable contactor 6 is engaged on opposite sides by the crossbar 11.
- THIS ACTION IS MADE FINAL. Applicant is reminded of the extension of time policy as set forth in 37 CFR 1.136(a).

Page 4

Application/Control Number: 10/549,813

Art Unit: 2832

A shortened statutory period for reply to this final action is set to expire THREE MONTHS from the mailing date of this action. In the event a first reply is filed within TWO MONTHS of the mailing date of this final action and the advisory action is not mailed until after the end of the THREE-MONTH shortened statutory period, then the shortened statutory period will expire on the date the advisory action is mailed, and any extension fee pursuant to 37 CFR 1.136(a) will be calculated from the mailing date of the advisory action. In no event, however, will the statutory period for reply expire later than SIX MONTHS from the mailing date of this final action.

Any inquiry concerning this communication or earlier communications from the
examiner should be directed to RAMON M. BARRERA whose telephone number is
(571)272-1987. The examiner can normally be reached on Monday through Friday from
11 to 5PM.

If attempts to reach the examiner by telephone are unsuccessful, the examiner's supervisor, Elvin G. Enad can be reached on (571) 272-1990. The fax phone number for the organization where this application or proceeding is assigned is 571-273-8300.

Application/Control Number: 10/549,813 Page 5

Art Unit: 2832

Information regarding the status of an application may be obtained from the Patent Application Information Retrieval (PAIR) system. Status information for published applications may be obtained from either Private PAIR or Public PAIR. Status information for unpublished applications is available through Private PAIR only. For more information about the PAIR system, see http://pair-direct.uspto.gov. Should you have questions on access to the Private PAIR system, contact the Electronic Business Center (EBC) at 866-217-9197 (toll-free). If you would like assistance from a USPTO Customer Service Representative or access to the automated information system, call 800-786-9199 (IN USA OR CANADA) or 571-272-1000.

/Ramon M Barrera/ Primary Examiner, Art Unit 2832

rmb